

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 08-51-00295  
Name of Facility: Kingsway Elementary School  
Address: 23300 Quasar Boulevard  
City, Zip: Port Charlotte 33952

**Correct By: Next Inspection  
Re-Inspection Date: None**

Type: Public School  
Owner: Charlotte County School Board  
Person In Charge: Rogala, Ronald Phone: (941) 255-7940

**Inspection Information**

Purpose: Routine  
Inspection Date: 3/22/2017

Begin Time: 01:30 PM  
End Time: 02:45 PM

**Additional Information**

FEMALES ..... 291  
MALES ..... 328

CENSUS ..... 619

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**Violation Markings**

SCHOOL SANITATION	11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
X 5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

**General Comments**

Overall the facility is well maintained.

Email Address(es): Ronald.Rogala@yourcharlotteschools.net

Inspector Signature:

*David Lee Pears*

Client Signature:

*Ed Winn*

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

Violation #5. Maintenance & Repair  
The interior of the microwave in the staff lounge is dirty.  
CODE REFERENCE: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

Inspection Conducted By: David Pears (31162)  
Inspector Contact Number: Work: (941) 743-1266 ex. 1507  
Print Client Name: Winn, Ed  
Date: 3/22/2017

Inspector Signature:

*David Lee Pears*

Client Signature:

*Ed Winn*